


incorporated 1783

Town of
LONGMEADOW, MASSACHUSETTS

170 Dwight Road – 01106
TEL (413) 567-3400 ~ FAX (413) 567-9018



DEPARTMENT OF PUBLIC WORKS

To: Lyn Simmons, Town Manager

From: Tim Keane, P.E., LSP, Town Engineer

Date: April 29, 2021

**Subject: Eversource Gas
Improvements near Gas Vault
Hillside Terrace at Longmeadow Street**

The Longmeadow DPW has reviewed the Project Description and accompanying plan set for the subject project as submitted by Eversource. The documentation describes planned construction within the existing buried vault, and the installation of some aboveground equipment (cabinet, bollards) immediately adjacent to the vault. Approval is recommended with the following conditions:

1. DIGSAFE must be contacted. A Town of Longmeadow Road Opening Permit is required prior to start of work.
2. Contact the Town Engineering Department at least 48 hours prior to start of work and report the day work will commence.
3. Contractor shall preserve and protect traffic signage in the area as well as the wooden guardrail adjacent to the work area.
4. No trees shall be removed or otherwise altered as part of the work.
5. Cabinet shall be painted green.
6. All disturbed areas shall be restored to original/better condition.
7. Contaminated soils or other contaminated media, if encountered, shall be removed at the expense of the applicant and properly managed in accordance with 310 CMR 40.0000.