

Minutes January 5, 2021

Longmeadow Permanent Building Committee

Attendance: Marybeth Bergeron, Committee Chair

Committee Members- Tom Ewing, Vincent McPartland, Mary Beth Morris, Jim Moulton, Peter Greenberg

- Meeting called to order at 3:08 PM for a walk through at the new DPW
- Walk through observations:
 - Guard rail should be installed near covered entrance
 - Guards should be installed around leaders near covered entrance
 - Wash bay floor—should be coated with an epoxy
 - Covers on hall lights—When will they be installed?
 - Check direction of grounds on receptacles
 - Main Entrance—should there be plexiglass?
- **Adult Center-** General roundtable discussion on center opening early 2021?
 - **PCO's-**
 - 93- RTU-Add power. Approved \$1401.00. Architect error/ omission
 - 97- add light fixture for sculpture. Approved \$2235.00. LACCF will fund
 - 101- Electrical wiring for gym entry. Approved \$2250.00. Architect error/ omission
 - 98- Northeast front porch column cap. Approved. \$487.00
 - 99-Paint accent wall. \$341.00. Approved. LACCF will fund
 - 100- Change electrical receptacles. \$1,015.00. Not approved if ivory
 - 102-Wiring for fireplace. \$1,985. Approved. Architect error/ omission
- **DPW-**
 - **PCO's-**
 - 85- pitch shower drain. \$915.38. Approved
 - 87- Delete ladder and rails in wash bay. Credit (\$4,425.40) delete ladder and rails at wash bay
 - 88- additional carpet because old model discontinued. \$3,399.95. Rejected again.
- Motion to adjourn at 4:08 PM. Approved.

Submitted by

Vincent J. McPartland

Vincent J. McPartland

January 6, 2021